



# CITY OF RIVERSIDE FIRE DEPARTMENT

## Incident Information Fact Sheet



**Incident Name:** Jurupa Inc  
**Incident Location:** 6097 Jurupa

**Type of Incident:** Outside Rubbish Fire  
**Incident Number:** 9470  
**Date Reported:** 04/03/2016  
**Time Reported:** 5:20 PM

**Fatalities:** 0 **Critical:** 0 **Moderate:** 0 **Minor:** 0 **Non Injury:** 0  
**Transported Ground Ambulance(s):** 0  
**Loss:** \$0  
**Save:** \$0  
**Cause:** Under Investigation

**Control Time:**

**Evacuations:** No  
**Evacuation Comments:**

### RESOURCES ASSIGNED

**Fire Fighters:** 17  
**Engine Companies:** 0  
**Truck Companies:** 0  
**Specialized Equipment:**

**Overhead Personnel:** 1  
**Ambulance(s):** 0  
**Water Tenders:** 0

**Utilities:** No  
**Red Cross:** No  
**Displaced Persons:** No

### CURRENT SITUATION

*(Recent updates are posted at the top of Current Situation)*

The City of Riverside Fire Department responded to a commercial structure fire at Prudential Overall Supply. Upon arrival of the first in fire unit they reported the fire to be an outside type fire of plastic crates filled with rags. The fire was about 50 feet long and 20 wide. The fire extended into the neighbor structure and caused damage to a metal awning. Their fire sprinklers kept the fire at bay. The fire was extinguished and the overhaul was extensive. Units were on scene for several hours overhauling the plastic crates. Once the crews were completed the building was turned over to the General Manager. The cause of the fire was under investigation.

### COOPERATING AGENCIES

CAL-Fire